



SHAKER HEIGHTS

Permit Requirements Propane Exchange Station

1. 18 20-lb. tanks maximum.
2. One (1) installation per site.
3. Outside of building at least ten (10) feet from any door frequented by the Public (per NFPA 58).
4. An enclosure (per NFPA 58) or lockable, ventilated metal locker or rack that prevents tampering with valves and pilferage.
5. Protection from vehicle impact.
6. Containers stored upright.
7. All containers shall have outlet plugs.
8. All containers shall meet DOT requirements.
9. Locker shall have placard for propane.
10. At least one (1) 18 lb. BC extinguisher on site.
11. Annual Permit Fee - \$50.00.